

Southeast Cooler Corporation



Walk-In Cooler & Freezer Panel Specifications

Southeast Cooler Meets the Mandated 2009 Energy Standards by Providing

Coolers with Insulating Materials having these R-Value Minimums:

6" Thick Laminated Expanded Polystyrene Panels (R-27)

4" Thick Extruded Polystyrene Panels (R-28)

3-1/2" Thick Foamed in Place Urethane Panels (R-25)

Freezers with Insulating Materials having these R-Value Minimums:

4" Thick Laminated Extruded Polystyrene (R-32)

4" Thick Laminated Urethane (R-32)

5'1/2" Thick Foamed in Place Urethane (R-39)

Doors Will include

- Spring Loaded Hinges
- Door Close Assist
- Strip Curtains